



Abu Dhabi/ Dubai

Client:

Project No: ABU DHABI-COM-RESOURCES

D = Defect

FIRE EXTINGUISHER INSPECTION LOG				Abu Dhabi/ Dubai			
Date: 07-11-2024	Time: 23:24:00.0000000	Location: mayyil			Client:		
Project Name: ABU DHABI-COM-RESOURCES			Project No: ABU DHABI-COM-RESOURCES				
√ = OK		N/A = Not Applicable			D = Defect		

Date of Inspection	Due date of Inspection	Extinguisher Tag No.	Volume of the Cylinder	Contents	Pressure Gauge	Hoses	Safety Pin	Remarks / Signature
--------------------	------------------------	----------------------	------------------------	----------	----------------	-------	------------	---------------------

Condition / fault to be checked:

Cylinder: - Free from damage, Label clean and legible, Owner clearly identified

Pressure Gauges: - Pressure reading within green section, Gauge clean and legible, Gauge free from damage

Contents: - Weight within specification, Cylinder inverted and bumped to loosen contents (for dry chemical only)

Hoses: - Free of obstruction, End cap in position, Connection checked for tightness, Free of cracks and deterioration

Safety Pin: - Secured from accidental displacement, Seal in place