



RAY International Electrical Equipments Maintenance LLC

RAY International Electrical Contracting LLC

RAY International Power LLC

### FIRE EXTINGUISHER INSPECTION LOG

Abu Dhabi/ Dubai

Date: 07-11-2024

Time: 12:49:00.0000000

Location: kkkkk

Client:

Project Name: ABU DHABI-COM-RESOURCES

Project No: ABU DHABI-COM-RESOURCES

✓ = OK

N/A = Not Applicable

D = Defect

| Date of Inspection | Due date of Inspection | Extinguisher Tag No. | Volume of the Cylinder | Contents | Pressure Gauge | Hoses | Safety Pin | Remarks / Signature |
|--------------------|------------------------|----------------------|------------------------|----------|----------------|-------|------------|---------------------|
| 06-11-2024         | 06-11-2024             | k                    | 1                      | CO2      | ✓              | ✓     | ✓          | gggh                |

Comments:

| Inspector       |                                                                                   |         |        | Site In charge  |                                                                                     |         |        |
|-----------------|-----------------------------------------------------------------------------------|---------|--------|-----------------|-------------------------------------------------------------------------------------|---------|--------|
| Name:           | Admin                                                                             |         |        | Name:           | Arbind Prasad                                                                       |         |        |
| Designation:    |                                                                                   |         |        | Designation:    |                                                                                     |         |        |
| Signature/Date: |  | RAY No: | RU/058 | Signature/Date: |  | RAY No: | RU/058 |

Condition / fault to be checked:

Cylinder: - Free from damage, Label clean and legible, Owner clearly identified

Pressure Gauges: - Pressure reading within green section, Gauge clean and legible, Gauge free from damage

Contents: - Weight within specification, Cylinder inverted and bumped to loosen contents (for dry chemical only)

Hoses: - Free of obstruction, End cap in position, Connection checked for tightness, Free of cracks and deterioration

Safety Pin: - Secured from accidental displacement, Seal in place

Ref No: FR-618

Version. No:

01

Issued Date :

08.09.2016

Page No:

Page 1 of 1