



RAY International Electrical Equipments Maintenance LLC

RAY International Electrical Contracting LLC

RAY International Power LLC

### FIRE EXTINGUISHER INSPECTION LOG

Abu Dhabi/ Dubai

Date: 23-10-2024

Time: 09:54:00.0000000

Location: dvdvd

Client:

Project Name: DUBAI-COM-RESOURCES

Project No: DUBAI-COM-RESOURCES

✓ = OK

N/A = Not Applicable

D = Defect

Date of Inspection	Due date of Inspection	Extinguisher Tag No.	Volume of the Cylinder	Contents	Pressure Gauge	Hoses	Safety Pin	Remarks / Signature
23-10-2024	23-10-2024	srre	4	DCP	D	D	D	

Comments: vgfbgfb

Inspector				Site In charge			
Name:	Admin			Name:	Vijaya Bhaskar Reddy		
Designation:				Designation:			
Signature/Date:			RAY No: RU/036	Signature/Date:			RAY No: RU/036

Condition / fault to be checked:

Cylinder: - Free from damage, Label clean and legible, Owner clearly identified

Pressure Gauges: - Pressure reading within green section, Gauge clean and legible, Gauge free from damage

Contents: - Weight within specification, Cylinder inverted and bumped to loosen contents (for dry chemical only)

Hoses: - Free of obstruction, End cap in position, Connection checked for tightness, Free of cracks and deterioration

Safety Pin: - Secured from accidental displacement, Seal in place

Ref No: FR-618

Version. No:

01

Issued Date :

08.09.2016

Page No:

Page 1 of 1