



FIRE EXTINGUISHER INSPECTION LOG			Abu Dhabi/ Dubai
Date: 24-10-2024	Time: 12:45:00.0000000	Location: est	Client:
Project Name: AL AIN-COM-RESOURCES		Project No: AL AIN-COM-RESOURCES	
√ = OK N/A = Not Applicable D = Defect			

Date of Inspection	Due date of Inspection	Extinguisher Tag No.	Volume of the Cylinder	Contents	Pressure Gauge	Hoses	Safety Pin	Remarks / Signature
--------------------	------------------------	----------------------	------------------------	----------	----------------	-------	------------	---------------------

Inspector				Site In charge				
Name:	Admin			Name:	Sudheer Thirumalmel Kalarickal			
Designation:				Designation:				
Signature/Date:		RAY No:	RU/022	Signature/Date:		RAY No:	RU/022	

Condition / fault to be checked:

Cylinder: - Free from damage, Label clean and legible, Owner clearly identified

Pressure Gauges: - Pressure reading within green section, Gauge clean and legible, Gauge free from damage

Contents: - Weight within specification, Cylinder inverted and bumped to loosen contents (for dry chemical only)

Hoses: - Free of obstruction, End cap in position, Connection checked for tightness, Free of cracks and deterioration

Safety Pin: - Secured from accidental displacement, Seal in place