



RAY International Electrical Equipments Maintenance LLC

RAY International Electrical Contracting LLC

RAY International Power LLC

### FIRE EXTINGUISHER INSPECTION LOG

Abu Dhabi/ Dubai

Date: 24-10-2024

Time: 12:45:00.0000000

Location: est

Client:

Project Name: AL AIN-COM-RESOURCES

Project No: AL AIN-COM-RESOURCES

✓ = OK

N/A = Not Applicable

D = Defect

Date of Inspection	Due date of Inspection	Extinguisher Tag No.	Volume of the Cylinder	Contents	Pressure Gauge	Hoses	Safety Pin	Remarks / Signature
24-10-2024	24-10-2024	sds	3	CO2	✓	N/A	D	er
24-10-2024	24-10-2024	ety	1	H2O	N/A	✓	D	rt

Comments: rtter

Inspector				Site In charge			
Name:	Admin			Name:	Sudheer Thirumalmel Kalarickal		
Designation:				Designation:			
Signature/Date:			RAY No: RU/022	Signature/Date:			RAY No: RU/022

Ref No: FR-618

Version. No:

01

Issued Date :

08.09.2016

Page No:

Page 1 of 2

FIRE EXTINGUISHER INSPECTION LOG							Abu Dhabi/ Dubai	
Date: 24-10-2024		Time: 12:45:00.0000000		Location: est		Client:		
Project Name: AL AIN-COM-RESOURCES				Project No: AL AIN-COM-RESOURCES				
v = OK			N/A = Not Applicable			D = Defect		
Date of Inspection	Due date of Inspection	Extinguisher Tag No.	Volume of the Cylinder	Contents	Pressure Gauge	Hoses	Safety Pin	Remarks / Signature
Condition / fault to be checked: Cylinder: - Free from damage, Label clean and legible, Owner clearly identified Pressure Gauges: - Pressure reading within green section, Gauge clean and legible, Gauge free from damage Contents: - Weight within specification, Cylinder inverted and bumped to loosen contents (for dry chemical only) Hoses: - Free of obstruction, End cap in position, Connection checked for tightness, Free of cracks and deterioration Safety Pin: - Secured from accidental displacement, Seal in place								