



RAY International Electrical Equipments Maintenance LLC

RAY International Electrical Contracting LLC

RAY International Power LLC

**FIRE EXTINGUISHER INSPECTION LOG**

Abu Dhabi/ Dubai

Date: 24-10-2024

Time: 21:24:00.0000000

Location: nnn

Client:

Project Name: ABU DHABI-COM-RESOURCES

Project No: ABU DHABI-COM-RESOURCES

V = OK

N/A = Not Applicable

D = Defect

| Date of Inspection | Due date of Inspection | Extinguisher Tag No. | Volume of the Cylinder | Contents | Pressure Gauge | Hoses | Safety Pin | Remarks / Signature |
|--------------------|------------------------|----------------------|------------------------|----------|----------------|-------|------------|---------------------|
| 24-10-2024         | 24-10-2024             | v                    | 9                      | CO2      | N/A            | ✓     | ✓          | jj                  |

Comments: mmmm

| Inspector       |     |         |        | Site In charge  |                      |         |        |
|-----------------|-----|---------|--------|-----------------|----------------------|---------|--------|
| Name:           | abc |         |        | Name:           | Vijil Israel Johnson |         |        |
| Designation:    |     |         |        | Designation:    |                      |         |        |
| Signature/Date: |     | RAY No: | RU/023 | Signature/Date: |                      | RAY No: | RU/023 |

Condition / fault to be checked:

Cylinder: - Free from damage, Label clean and legible, Owner clearly identified

Pressure Gauges: - Pressure reading within green section, Gauge clean and legible, Gauge free from damage

Contents: - Weight within specification, Cylinder inverted and bumped to loosen contents (for dry chemical only)

Hoses: - Free of obstruction, End cap in position, Connection checked for tightness, Free of cracks and deterioration

Safety Pin: - Secured from accidental displacement, Seal in place

Ref No: FR-618

Version. No:

01

Issued Date :

08.09.2016

Page No:

Page 1 of 1