



RAY International Electrical Equipments Maintenance LLC

RAY International Electrical Contracting LLC

RAY International Power LLC

FIRE EXTINGUISHER INSPECTION LOG

Abu Dhabi/ Dubai

Date: 29-10-2024	Time: 09:23:00.0000000	Location: admin	Client:
Project Name: ABU DHABI-COM-RESOURCES		Project No: ABU DHABI-COM-RESOURCES	
✓ = OK		N/A = Not Applicable	
		D = Defect	

Date of Inspection	Due date of Inspection	Extinguisher Tag No.	Volume of the Cylinder	Contents	Pressure Gauge	Hoses	Safety Pin	Remarks / Signature
29-10-2024	29-10-2024	q	1	CO2	✓	✓	✓	

Comments:	ff
-----------	----

Inspector			Site In charge		
Name:	Admin		Name:	Sudheer Thirumalmel Kalarickal	
Designation:			Designation:		
Signature/Date:		RAY No: RU/022	Signature/Date:		RAY No: RU/022

Condition / fault to be checked:

Cylinder: - Free from damage, Label clean and legible, Owner clearly identified

Pressure Gauges: - Pressure reading within green section, Gauge clean and legible, Gauge free from damage

Contents: - Weight within specification, Cylinder inverted and bumped to loosen contents (for dry chemical only)

Hoses: - Free of obstruction, End cap in position, Connection checked for tightness, Free of cracks and deterioration

Safety Pin: - Secured from accidental displacement, Seal in place