



RAY International Electrical Equipments Maintenance LLC

RAY International Electrical Contracting LLC

RAY International Power LLC

### FIRE EXTINGUISHER INSPECTION LOG

Abu Dhabi/ Dubai

Date: 13-05-2025

Time: 10:42 AM

Location: knr

Client: client-247

Project Name: Project-247

Project No: Project-247

✓ = OK

N/A = Not Applicable

D = Defect

| Date of Inspection | Due date of Inspection | Extinguisher Tag No. | Volume of the Cylinder | Contents | Pressure Gauge | Hoses | Safety Pin | Remarks / Signature |
|--------------------|------------------------|----------------------|------------------------|----------|----------------|-------|------------|---------------------|
| 13-05-2025         | 13-05-2025             | t                    | 1 Kg                   | CO2      | ✓              | N/A   | N/A        | qwe                 |

Comments: S

| Inspector       |                                                                                              |         |        | Site In charge  |                     |         |        |
|-----------------|----------------------------------------------------------------------------------------------|---------|--------|-----------------|---------------------|---------|--------|
| Name:           | VINI11                                                                                       |         |        | Name:           | Employee-16         |         |        |
| Designation:    | Steel Fitter                                                                                 |         |        | Designation:    | Mechanical Engineer |         |        |
| Signature/Date: |  13-05-2025 | RAY No: | Emp-40 | Signature/Date: |                     | RAY No: | Emp-16 |

Condition / fault to be checked:

Cylinder: - Free from damage, Label clean and legible, Owner clearly identified

Pressure Gauges: - Pressure reading within green section, Gauge clean and legible, Gauge free from damage

Contents: - Weight within specification, Cylinder inverted and bumped to loosen contents (for dry chemical only)

Hoses: - Free of obstruction, End cap in position, Connection checked for tightness, Free of cracks and deterioration

Safety Pin: - Secured from accidental displacement, Seal in place

Ref No: FR-618

Version. No:

01

Issued Date :

08.09.2016

Page No:

Page 1 of 1