

RAY International Electrical Equipments Maintenance LLC

RAY International Electrical Contracting LLC

RAY International Power LLC

FIRE EXTINGUISHER INSPECTION LOG								Abu Dhabi/ Dubai				
Date: 09-11-2024 Time: 10:45:00.0000000				Location: location added location added location				Client:				
Project Name:	Project Name: ABU DHABI-COM-RESOURCES Project No: ABU DHABI-COM-RESOURCES											
√ = OK	V = OK N/A = Not Applicable D = Defect									D = Defect		
Date of Inspection	Due date Inspection		Extinguisher Tag No.	Volume o	I	Contents		Pressure Gauge	Hoses		Safety Pin	Remarks / Signature
09-11-2024	11-09-20	24	r	1 Kg		CO2		✓	N/A		N/A	9999
Comments:			on added location			d location added	location a	dded location ad	ded location	added loca	tion added lo	ocation added

Inspector		Site In charge						
Name:	sijinauser			Name:	Benard Wasike Nyongesa			
Designation:				Designation:				
Signature/Date:	ELGO	RAY No:	RU/212	Signature/Date:	ELGO	RAY No:	RU/212	

Condition / fault to be checked:

Cylinder: - Free from damage, Label clean and legible, Owner clearly identified

Pressure Gauges: - Pressure reading within green section, Gauge clean and legible, Gauge free from damage

Contents: - Weight within specification, Cylinder inverted and bumped to loosen contents (for dry chemical only)

Hoses: - Free of obstruction, End cap in position, Connection checked for tightness, Free of cracks and deterioration

Safety Pin: - Secured from accidental displacement, Seal in place

	Version. No:	Issued Date :	08.09.2016	Page No:	Page 1 of 1
--	--------------	---------------	------------	----------	-------------