



RAY International Electrical Equipments Maintenance LLC

RAY International Electrical Contracting LLC

RAY International Power LLC

FIRE EXTINGUISHER INSPECTION LOG

Abu Dhabi/ Dubai

Date: 05-11-2024

Time: 14:58:00.0000000

Location: aa

Client: Client ABC

Project Name: Project A

Project No: PRJ_A



V = OK

N/A = Not Applicable

D = Defect

Date of Inspection	Due date of Inspection	Extinguisher Tag No.	Volume of the Cylinder	Contents	Pressure Gauge	Hoses	Safety Pin	Remarks / Signature
05-11-2024	05-11-2024	54	3	H2O	D	D	D	gsshshshshshshshs

Comments: hdjdjdbdjddjdjdjnddbdnjdjdbdb

Inspector				Site In charge			
Name:	testuser			Name:	Arbind Prasad		
Designation:				Designation:			
Signature/Date:		RAY No:	RU/058	Signature/Date:		RAY No:	RU/058

Condition / fault to be checked:

Cylinder: - Free from damage, Label clean and legible, Owner clearly identified

Pressure Gauges: - Pressure reading within green section, Gauge clean and legible, Gauge free from damage

Contents: - Weight within specification, Cylinder inverted and bumped to loosen contents (for dry chemical only)

Hoses: - Free of obstruction, End cap in position, Connection checked for tightness, Free of cracks and deterioration

Safety Pin: - Secured from accidental displacement, Seal in place

Ref No: FR-618

Version. No:

01

Issued Date :

08.09.2016

Page No:

Page 1 of 1