

RAY International Electrical Equipments Maintenance LLC

RAY International Electrical Contracting LLC

RAY International Power LLC

FIRE EXTINGUISHER INSPECTION LOG											Abu Dhabi/ Dubai			
Date: 09-11-2024 Time: 10:45:00.00000				000	Location: location added location added location					Client:				
Project Name:	ABU DH	ABI-CC	M-RESOURCES			o: ABU DHABI-COM-RESOURCES								
V = OK N/A = Not Applicable										D = Defect				
Date of Inspection	Due date Inspecti		Extinguisher Tag No.	Volum e of		Contents		Pressure Gauge	Hoses	Safety Pin	Remarks / Signature			
09-11-2024	11-09-2024		r	1 Kg		CO2		✓	N/A	N/A	9999			
Comments: location added														
Inspector					Site In charge									
Name: sijinauser								Name:	Benard	Benard Wasike Nyongesa				
Designation:								Designation:						
Signature/Date:		RAY No:		RU/212		Signature/Date:	\bigcirc	LL	RAY No: RU/212					

Condition / fault to be checked:

Cylinder: - Free from damage, Label clean and legible, Owner clearly identified

Pressure Gauges: - Pressure reading within green section, Gauge clean and legible, Gauge free from damage

Contents: - Weight within specification, Cylinder inverted and bumped to loosen contents (for dry chemical only)

Hoses: - Free of obstruction, End cap in position, Connection checked for tightness, Free of cracks and deterioration

Safety Pin: - Secured from accidental displacement, Seal in place

	ersion. No:	Issued Date :	08.09.2016	Page No:	Page 1 of 1	
--	-------------	---------------	------------	----------	-------------	--