



RAY International Electrical Equipments Maintenance LLC

RAY International Electrical Contracting LLC

RAY International Power LLC

FIRE EXTINGUISHER INSPECTION LOG

Abu Dhabi/ Dubai

Date: 25-10-2024

Time: 17:39:00.0000000

Location: knr

Client:

Project Name: ABU DHABI-COM-RESOURCES

Project No: ABU DHABI-COM-RESOURCES

✓ = OK

N/A = Not Applicable

D = Defect

Date of Inspection	Due date of Inspection	Extinguisher Tag No.	Volume of the Cylinder	Contents	Pressure Gauge	Hoses	Safety Pin	Remarks / Signature
25-10-2024	30-10-2024	2	2	CO2	✓	✓	✓	

Comments: mmmmmmmmmmmmmmmmmmmmmjnbjlb bjbllbbbbbbbbbbbbb nbm,j

Inspector				Site In charge			
Name:	Admin			Name:	Sudheer Thirumalmel Kalarickal		
Designation:				Designation:			
Signature/Date:		RAY No:	RU/022	Signature/Date:		RAY No:	RU/022

Condition / fault to be checked:

Cylinder: - Free from damage, Label clean and legible, Owner clearly identified

Pressure Gauges: - Pressure reading within green section, Gauge clean and legible, Gauge free from damage

Contents: - Weight within specification, Cylinder inverted and bumped to loosen contents (for dry chemical only)

Hoses: - Free of obstruction, End cap in position, Connection checked for tightness, Free of cracks and deterioration

Safety Pin: - Secured from accidental displacement, Seal in place

Ref No: FR-618

Version. No:

01

Issued Date :

08.09.2016

Page No:

Page 1 of 1