



Abu Dhabi/ Dubai

Client: client-187

Project No: Project-187

D = Defect

Page 1 of 2

FIRE EXTINGUISHER INSPECTION LOG				Abu Dhabi/ Dubai	
Date: 11-11-2024	Time: 22:41:00.0000000	Location: porora		Client: client-187	
Project Name: Project-187			Project No: Project-187		
✓ = OK		N/A = Not Applicable		D = Defect	

Date of Inspection	Due date of Inspection	Extinguisher Tag No.	Volume of the Cylinder	Contents	Pressure Gauge	Hoses	Safety Pin	Remarks / Signature
Inspector					Site In charge			
Name:	VINI11				Name:	Employee-8		
Designation:					Designation:			
Signature/Date:			RAY No: Emp-8		Signature/Date:			RAY No: Emp-8

Condition / fault to be checked:

Cylinder: - Free from damage, Label clean and legible, Owner clearly identified

Pressure Gauges: - Pressure reading within green section, Gauge clean and legible, Gauge free from damage

Contents: - Weight within specification, Cylinder inverted and bumped to loosen contents (for dry chemical only)

Hoses: - Free of obstruction, End cap in position, Connection checked for tightness, Free of cracks and deterioration

Safety Pin: - Secured from accidental displacement, Seal in place

Ref No: FR-618	Version. No:	01	Issued Date :	08.09.2016	Page No:	Page 2 of 2
----------------	--------------	----	---------------	------------	----------	-------------