



RAY International Electrical Equipments Maintenance LLC

RAY International Electrical Contracting LLC

RAY International Power LLC

FIRE EXTINGUISHER INSPECTION LOG

Abu Dhabi/ Dubai

Date: 06-11-2024

Time: 01:46:00.0000000

Location: hm

Client:

Project Name: TestPrinchu

Project No: Test



✓ = OK

N/A = Not Applicable

D = Defect

Date of Inspection	Due date of Inspection	Extinguisher Tag No.	Volume of the Cylinder	Contents	Pressure Gauge	Hoses	Safety Pin	Remarks / Signature
06-11-2024	03-11-2024	67	56	H2O	N/A	N/A	N/A	bnn
06-11-2024	23-11-2024	46	59	H2O	N/A	N/A	N/A	bn

Comments: vnnn

Inspector			Site In charge		
Name:	VINI11		Name:	Mirza Habeeb Baig	
Designation:			Designation:		
Signature/Date:		RAY No: RU/031	Signature/Date:		RAY No: RU/031

Condition / fault to be checked:

Cylinder: - Free from damage, Label clean and legible, Owner clearly identified

Pressure Gauges: - Pressure reading within green section, Gauge clean and legible, Gauge free from damage

Contents: - Weight within specification, Cylinder inverted and bumped to loosen contents (for dry chemical only)

Hoses: - Free of obstruction, End cap in position, Connection checked for tightness, Free of cracks and deterioration

Safety Pin: - Secured from accidental displacement, Seal in place

Ref No: FR-618

Version. No:

01

Issued Date :

08.09.2016

Page No:

Page 1 of 1