



RAY International Electrical Equipments Maintenance LLC

RAY International Electrical Contracting LLC

RAY International Power LLC

FIRE EXTINGUISHER INSPECTION LOG

Abu Dhabi/ Dubai

Date: 24-10-2024

Time: 21:24:00.0000000

Location: nnn

Client:

Project Name: ABU DHABI-COM-RESOURCES

Project No: ABU DHABI-COM-RESOURCES

V = OK

N/A = Not Applicable

D = Defect

Date of Inspection	Due date of Inspection	Extinguisher Tag No.	Volume of the Cylinder	Contents	Pressure Gauge	Hoses	Safety Pin	Remarks / Signature
24-10-2024	24-10-2024	v	9	CO2	N/A	✓	✓	jj

Comments: mmmm

Inspector				Site In charge			
Name:	abc			Name:	Vijil Israel Johnson		
Designation:				Designation:			
Signature/Date:		RAY No:	RU/023	Signature/Date:		RAY No:	RU/023

Condition / fault to be checked:

Cylinder: - Free from damage, Label clean and legible, Owner clearly identified

Pressure Gauges: - Pressure reading within green section, Gauge clean and legible, Gauge free from damage

Contents: - Weight within specification, Cylinder inverted and bumped to loosen contents (for dry chemical only)

Hoses: - Free of obstruction, End cap in position, Connection checked for tightness, Free of cracks and deterioration

Safety Pin: - Secured from accidental displacement, Seal in place

Ref No: FR-618

Version. No:

01

Issued Date :

08.09.2016

Page No:

Page 1 of 1