

## **RAY International Electrical Contracting & Maintenance LLC**

## **RAY International Electrical Contracting LLC**

**RAY International Power LLC** 

## INCIDENT NOTIFICATION To be reported within 24 hours (maximum)

Abudhabi/ Dubai

ISTRIBUTIONT ID, CEO, GMs,	o. Discipline SR MGR, QHSE MGF	R & advisors	s, LINE Manage	ers, HRA M	anager						
EPORT ORIGII	•		<u>,                                     </u>								
NAME:	Fawad Zaman	COMPAN		RU/23/F	PRJ/00045 GSM NO: 0			050 97714	050 9771473		
LOCATION OF INCIDENT:	OF Aweer 132 kV substation DATE OF INCIDENT:			DENT:	04-07-2024	TIME:		08:59			
INCIDENT TYPE:	Near Miss										
	CIDENT ACTUAL SEVERITY RATING: 3  DIENTIAL SEVERITY RATING: 3				Likelihood Severity	Rare (1)	Unlikely Poss		Likely (4)	Almost Certain (5)	
RISKLEVEL:		Мо	derate		Catastrophic (5)	_				.,	
Note:						Low	Moderate	High	_	High	
Use the Risk Assessment Matrix to determine the <b>actual</b> and <b>potential</b> severity rating for the incident. Seek assistance from the HSE Advisor if required.					Major (4) Moderate (3)	Low	Moderate Moderate	Modera Modera		High	
en al danska sodela a						Low	Moderate	Modera	_	High Moderate	
Incidents with a potential 'Medium or High Risk' shall be referred to the RAY QHSE Dept immediately					Minor (2) Negligible (1)	Low	Low	Low		Low	
Low	Moderate	Hig	gh		Trigugues (1)	2511	2011	Dom	2.5.11	2011	
			BRIEF I	DESCRIPTIO	N OF INCIDENT						
found hydra	ulic oil leakage at outrigge	rs jacks h	ose in our 3	Ton HIA	B 65761.						
			BRIEF	DESCRIPTIO	N OF DAMAGE						
outrigger jac	ks not in good level. jacks	bends to	wards front	side and	also their is leal	kage in h	ydrolic hos	€.			
JMBER OF PERS	ONS INJURED:		0								
	RED PEOPLE AND DETAILS OF INJ	URIES.	nil								
			FOLLOWING	FOR <u>LOW </u>	POTENTIAL INCIDE	NTS-					
	(All incidents in	cluding Me	dium or High P	otential <u>M</u>	<u>UST</u> have a full inve	stigation r	eport comple	ted)			
IMMEDIATE CAUSES	leakage in h	ydrolic ho	ses								
UNDERLYING CAUSES	need proper			equipme	nt.						
_	CORRECTIVE AND PREVENTIVE ACTIONS:					RESPONSIBLE:			CLOSED DATE:		
vehicle inspection and maintenance should be maintained for the vehic					hicles.	Mustak Ahmad			10/07	10/07/2024	
vvgg						Sudheer Thirumalmel Kalarickal			bh		

Ref No:	RAY-IMS-FR-627	Version. No	01	Issued Date	9/7/2024	Page No	1	PreparedBy	RAY International
---------	----------------	-------------	----	-------------	----------	---------	---	------------	-------------------